

A

03000EE301092001

Pages: 3

Reg No.: _____

Name: _____

APJ ABDUL KALAM TECHNOLOGICAL UNIVERSITY

B.Tech S5 (S) Examination September 2020



Course Code: EE301

Course Name: **POWER GENERATION, TRANSMISSION AND PROTECTION**

Max. Marks: 100

Duration: 3 Hours

PART A

Answer all questions, each carries 5 marks.

- | | | Marks |
|---|---|-------|
| 1 | Explain the general arrangement and operation of a hydro electric power plant. | (5) |
| 2 | The receiving end voltage of an unloaded long line may be more than the sending end voltage. Explain this phenomenon with the help of a phasor diagram. | (5) |
| 3 | Explain Kelvin's law. What are its limitations? | (5) |
| 4 | Describe the phenomenon of corona. Explain any three factors which affect corona loss. | (5) |
| 5 | Explain the arc quenching theorems in a circuit breaker. | (5) |
| 6 | Explain the fundamental requirements of protective relaying. | (5) |
| 7 | Differentiate between surge diverter and surge absorber. What are the characteristics of an ideal surge diverter. | (5) |
| 8 | Explain briefly various systems of primary distribution in the case of ac. | (5) |

PART B

Answer any two full questions, each carries 10 marks.

- | | | |
|----|--|-----|
| 9 | a) Define the term Diversity factor and prove that the load factor of a supply system is improved by an increase in diversity of load. | (5) |
| | b) Find the sending end voltage and voltage regulation of a 250 km, 3 phase, 50 Hz transmission line delivering 25 MVA at 0.8 pf lag to a balanced load at 132 kV. The inductance of the line is 1.25mH/km/ph and the shunt capacitance is 0.0095 μ F/km/ph. Use nominal π method. | (5) |
| 10 | a) From first principles, derive the equation for the loop inductance of a single phase overhead line. | (5) |
| | b) A synchronous motor improves the power factor of a load of 250 kW from 0.75 | (5) |

to 0.9 lagging. Simultaneously the motor carries a load of 100 kW. Find (1) the leading KVAR taken by the motor (2) KVA rating of the motor and pf at which the motor operates.

- 11 a) With the help of block diagrams explain the working of a solar power plant and a wind power plant. (5)
- b) Derive the capacitance of a single phase transmission line, considering the effect of earth. (5)

PART C

Answer any two full questions, each carries 10 marks.

- 12 a) Explain the configuration of FC+ TCR. (5)
- b) A single core cable has a conductor radius 2 cm and inside sheath radius 4 cm. It is provided with one inter sheath so that limits of maximum and minimum electric stresses is the same in the two layers of dielectric. The system voltage is 66kV, 3 phase. (5)
Find (a) the radius of inter sheath and its voltage (b) the ratio of maximum electric stress with and without inter sheath.
- 13 a) Explain the power transfer equations in ac transmission and dc transmission. (5)
- b) A string of 5 suspension insulators is to be graded for obtaining uniform voltage distribution across the string. If the pin to earth capacitance are all equal to C and the mutual capacitance of the top insulator is 10 C, find the mutual capacitance of each unit in terms of C. (5)
- 14 a) Classify the types of HVDC links and explain the construction and working of each type with the help of necessary diagrams. (5)
- b) Assuming that the shape of an over head line can be approximated by a parabola, derive the expression for sag. How the effect of wind and ice loadings can be taken into account. (5)

PART D

Answer any two full questions, each carries 10 marks.

- 15 a) Compare the arc rupture in oil and air blast circuit breakers and summarize the relative advantages and disadvantages of these types of switch gears. (5)
- b) With the help of a neat diagram explain the Buchholz's protection for transformers. (5)
- 16 a) Explain how an amplitude comparator can be converted to a phase comparator and vice versa. (5)

- b) What are the causes of over voltages arising on a power system? (3)
- c) Explain the term insulation co ordination. (2)
- 17 a) Draw a neat sketch of an induction disc relay and explain its construction and operation. (5)
- b) A dc two wire distributor AB of 300m long is fed at both ends A and B. It supplies uniformly distributed load of 0.15A/m and concentrated loads of 50A, 60A and 40A at distances of 75m, 175m and 225m respectively from the end A. The potentials of feeding points A and B are 206 V and 200 V respectively. The resistance of each wire is 0.00015 ohm/m. Find the currents fed at points A and B. (5)
